

AENOR

Certificate of constancy of performance

CE
0099

0099/CPR/B85/0753

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

ERSE KABLO SANAYI VE TICARET A.S.

registered office	HALIL RIFAT PASA MAHALLESİ YÜZER HAVUZ SOKAK NO:5-9 34384 ISTANBUL (Sisli - Turkey)
Certified performance	Reaction to Fire of power electric cables for general applications in construction Works.
Harmonised Standard	EN 50575:2014 EN 50575:2014/A1:2016
Designation	RZ1-K (AS+)
Trade Mark	ERSE
Reaction to Fire Class	Cca-s1a,d1,a1
Cross-sectional Range	1x70 mm ² ; 1x95 mm ² ; 1x120 mm ² ; 1x150 mm ² ; 1x185 mm ² ; 1x240 mm ² ; 1x300 mm ² .
Rated Voltage	0,6/1 kV
Generic Power Cable Family	Single core sheathed (unarmoured)
Production site	ORTAKÖY SANAYİ BÖLGESİ, ELİF SOKAK NO:12 34592 ISTANBUL (Silviri - Turkey)
Certification scheme	This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied. This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.
First issued on	2021-09-21
Validity date	2024-09-21


Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Control body accredited by ENAC. Accreditation number: 1/C-PR356